



CONSTRUCTION MATERIALS

TECHNOLOGIES

Email

TO: Glenn Summers - ConselcoR, Inc **DATE:** January 23, 2009
FROM: Don Portfolio *[Signature]*
SUBJECT: Test Status: VOC of StableCrete

Please find following the results of this testing:

| Property | ASTM Test Method | Result |
|--|------------------|--------|
| Volatile Organic Compounds (VOC), g/l | D 3960 | 13 |
| Volatile Organic Compounds (VOC), lb/gal | D 3960 | 0.1 |

Note: VOC is less water.

CNSL-001-02-01 PRI Accreditations: IAS-ES TL-189; State of Florida TST5878; Metro-Dade 06-1116.02; CRRC
 The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

PRI Construction Materials Technologies LLC 6408 Badger Drive Tampa, FL 33610 Tel: 813-621-5777 Fax: 813-621-5840 e-mail dportfolio@pricmt.com WebSite: http://www.pricmt.com